



Product Service

Attestation of Conformity

No. N8A 113647 0004 Rev. 00

Holder of Certificate: **Daxler Enerji A.S**
Büyükkayacik OSB. 102.
Cad. No:3/1 Selcuklu
42160 Konya
TURKEY

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062134702-00

Date, 2022-01-21

(David Bo)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 113647 0004 Rev. 00

Model(s):

WM10-144-HCG-xxx, xxx=530 to 555, in step of 5
 WM10-132-HCG-xxx, xxx=485 to 500, in step of 5
 WM10-120-HCG-xxx, xxx=440 to 455, in step of 5
 WM10-108-HCG-xxx, xxx=395 to 410, in step of 5
 WM6-144-HCG-xxx, xxx=430 to 450, in step of 5
 WM6-132-HCG-xxx, xxx=395 to 410, in step of 5
 WM6-120-HCG-xxx, xxx=360 to 375, in step of 5
 WM12-132-HCG-xxx, xxx=645 to 665, in step of 5
 WM12-120-HCG-xxx, xxx=585 to 605, in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors
Test Laboratory:	Changzhou Huan Yang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China.
Safety Class:	Class II
Maximum System Voltage:	1500 VDC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.